



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

The school district is following all recommended remediation to help reduce children's overall exposure to lead in drinking water.

School District: Highline

School Name: Puget Sound Skills Center

School Code: 2270

School Address: 18010 8th Ave S, Seattle Washington 98148

Number of Samples Collected: 57

Date Collected: 03/15/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
21129	other			<1	03/29/2019	
21130	FirstDraw	Bubbler	Across from Main Office	<1	03/29/2019	
21131	FirstDraw	BottleFiller	Across from Main Office	<1	03/29/2019	
21132	FirstDraw	Tap	Restraurant coffee machine sink	3	03/29/2019	
21133	FirstDraw	BottleFiller	Restaurant Coffee Machine	3	03/29/2019	
21134	FirstDraw	Tap	Service Area	<1	03/29/2019	
21135	FirstDraw	BottleFiller	Service Area	<1	03/29/2019	
21136	FirstDraw	Tap	Island Double Sink	7	03/29/2019	Above metal bowl storage
21137	FirstDraw	Tap	Single sink at end of stove line	<1	03/29/2019	
21138	FirstDraw	Tap	Sink sink Boning Knives Station	1	03/29/2019	
21139	FirstDraw	Bubbler	Left of Electrical Room	1	03/29/2019	Outside kitchen in hall
21140	FirstDraw	Tap	Office Staff Room	1	03/29/2019	
21141	FirstDraw	Tap	Green Room	66	03/29/2019	
21142	FirstDraw	Bubbler	Next to Custodian Room and Student Commons	1	03/29/2019	
21143	FirstDraw	Tap	Firefighter Room	4	03/29/2019	East
21144	FirstDraw	Tap	Firefighter Room	4	03/29/2019	West

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
21145	FirstDraw	Bubbler	Dental/Cleric Entryway	1	03/29/2019	
21146	FirstDraw	Tap	Outdoor Research	54	03/29/2019	South Table Clockwise from Front Right Sink 1
21147	FirstDraw	Tap	Outdoor Recreation	49	03/29/2019	Sink 2
21148	FirstDraw	Tap	Outdoor Recreation	35	03/29/2019	Sink 3
21149	FirstDraw	Tap	Outdoor Recreation	18	03/29/2019	Sink 4
21151	FirstDraw	Tap	Outdoor Recreation	45	03/29/2019	North Table clockwise from Front Right Sink 1
21152	FirstDraw	Tap	Outdoor Recreation	34	03/29/2019	Sink 2
21153	FirstDraw	Tap	Outdoor Recreation	99	03/29/2019	Sink 3
21154	FirstDraw	Tap	Outdoor Recreation	16	03/29/2019	Sink 4
21155	FirstDraw	Bubbler	Outside VITAL	<1	03/29/2019	
21156	FirstDraw	Tap	VITAL Kitchenette	<1	03/29/2019	
21157	FirstDraw	Bubbler	Woodshop	13	03/29/2019	East
21158	FirstDraw	Bubbler	Woodshop	9	03/29/2019	West
21159	FirstDraw	Bubbler	Automotive	1	03/29/2019	
21160	FirstDraw	Bubbler	Body Shop	1	03/29/2019	
21161	FirstDraw	Tap	Body Shop	3	03/29/2019	Left tap on triple tap sink
21162	FirstDraw	Bubbler	Dental Suite Across from Rm 1340	<1	03/29/2019	Left

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
21163	FirstDraw	Bubbler	Dental Suite Across from Rm 1340	2	03/29/2019	Right
21164	FirstDraw	Tap	Rm 1341	<1	03/29/2019	
21165	FirstDraw	Tap	Rm 1341	<1	03/29/2019	
21166	FirstDraw	Tap	Rm 1320	<1	03/29/2019	Side counter left sink
21167	FirstDraw	Tap	Rm 1320	<1	03/29/2019	Side counter right sink
21168	FirstDraw	Tap	Rm 1320	<1	03/29/2019	Dental Bay 1
21169	FirstDraw	Tap	Rm 1320	<1	03/29/2019	Dental Bay 2
21170	FirstDraw	Tap	Rm 1320	<1	03/29/2019	Dental Bay 3
21171	FirstDraw	Tap	Rm 1328	1	03/29/2019	
21173	FirstDraw	Tap	Rm 1312	1	03/29/2019	West
21173	FirstDraw	Tap	Rm 1312	1	03/29/2019	East
21174	FirstDraw	Tap	Dental Clinic	<1	03/29/2019	Side prep sink
21175	FirstDraw	Tap	Dental clinic	<1	03/29/2019	Room 1
21176	FirstDraw	Tap	Rm 1423	<1	03/29/2019	
21177	FirstDraw	Tap	Dental clinic	<1	03/29/2019	Rm 2
21178	FirstDraw	Tap	Dental clinic	<1	03/29/2019	Rm 4
21179	other	Tap	Dental clinic staff room	<1	03/29/2019	
21180	FirstDraw	Tap	Rm 1117	<1	03/29/2019	Single sink
21181	FirstDraw	Tap	Rm 1117	<1	03/29/2019	Double sink left tap
21182	FirstDraw	Tap	Rm 1117	1	03/29/2019	Double sink right tap

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
21183	FirstDraw	Bubbler	Across from Rm 2310	<1	03/29/2019	Left
21184	FirstDraw	Bubbler	Across from Rm 2310	<1	03/29/2019	Right
21185	FirstDraw	Tap	Nursing Lab	<1	03/29/2019	Sink under microwave
21186	FirstDraw	Tap	Rm 2340	1	03/29/2019	